

120-
100-
80-
60-
40-
20-
0-



DRAINAGE EXISTING CONDITIONS

Karen Longteig
APRIL 2008

CONNECT OVERFLOW TO CHAMBERS

BARNES PLACE

TIE IN TO 12" ϕ PIPE PUT IN 2010
6" PERF ~~PIPE~~ PVC MIN. 6" BELOW FLOOR.


POROUS PAVING

DRIVEWAY

DRIVEWAY

A.D. TYP.

GET TOWN TO FIX DRAIN LINE TO STREET.



clogged 10' out, 11' deep but drains out rapidly

54' from FFK drain 12' below grade

clogged at 3' 35' from FFK drain

(under wall between RE closet & better room)

FFK drain

grate drain

3' clogged at 4-5' into lawn

LAWN

flooder drain @ 4' below present grade slay pipe, loose joints. May be perforated on lower side?

Kitchen exterior storm drain

access panel under pass-through

half obstructed @ 4' clean-out, main sewer

Side door drain

rain leader (down spout connected directly into below grade pipe)

CBS